



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 11/29/2021  
Received: 11/16/2021  
Sampled By:  
Work Order: 1322002

**C** **Molalla River School District**  
**L** Attn: Tony Tiano  
**I** 412 S Sweigle Ave  
**E** Molalla OR, 97038  
**N** Phone: (503) 915-5248  
**T**

**Project:** Mulino Elementary School  
**Project # :** -  
**Sample Type :**

Sampling Location:

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>1322002-01</b>	<b>Sample Name:</b> Room 20 FA <b>Sampled:</b> 11/11/21 14:16		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	4	ppb	2	15 ppb	11/22/21 15:29
<b>1322002-02</b>	<b>Sample Name:</b> Room 21 FA <b>Sampled:</b> 11/11/21 14:15		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/22/21 15:29
<b>1322002-03</b>	<b>Sample Name:</b> Room 22 FA <b>Sampled:</b> 11/11/21 14:15		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	4	ppb	2	15 ppb	11/22/21 15:29
<b>1322002-04</b>	<b>Sample Name:</b> Boys RR R N . BLDL <b>Sampled:</b> 11/11/21 15:09		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/22/21 15:29
<b>1322002-05</b>	<b>Sample Name:</b> Boys RR L N . BLDL <b>Sampled:</b> 11/11/21 15:09		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	2	ppb	2	15 ppb	11/22/21 15:29
<b>1322002-06</b>	<b>Sample Name:</b> Grils RR R N . BLDL <b>Sampled:</b> 11/11/21 15:08		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/22/21 15:29
<b>1322002-07</b>	<b>Sample Name:</b> Grils RR L N . BLDL <b>Sampled:</b> 11/11/21 15:08		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/22/21 15:29
<b>1322002-08</b>	<b>Sample Name:</b> KITCHEN TRIPLE SINK <b>Sampled:</b> 11/11/21 14:11		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	2	ppb	2	15 ppb	11/22/21 15:29
<b>1322002-09</b>	<b>Sample Name:</b> KITCHEN DEEP SINK <b>Sampled:</b> 11/11/21 14:11		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	2	ppb	2	15 ppb	11/22/21 15:29
<b>1322002-10</b>	<b>Sample Name:</b> KITCHEN RR SINK <b>Sampled:</b> 11/11/21 14:12		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/22/21 15:29



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 11/29/2021  
Received: 11/16/2021  
Sampled By:  
Work Order: 1322002

**C** **Molalla River School District**  
**L** Attn: Tony Tiano  
**I** 412 S Sweigle Ave  
**E** Molalla OR, 97038  
**N** Phone: (503) 915-5248  
**T**

**Project:** Mulino Elementary School  
Project # : -  
Sample Type :

Sampling Location:

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>1322002-11</b>	<b>Sample Name:</b> SINK RM FA <b>Sampled:</b> 11/11/21 14:01		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	2	ppb	2	15 ppb	11/22/21 15:29
<b>1322002-12</b>	<b>Sample Name:</b> ROOM 11 FA <b>Sampled:</b> 11/11/21 14:02		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	3	ppb	2	15 ppb	11/22/21 15:29
<b>1322002-13</b>	<b>Sample Name:</b> Boys RR L N.B. <b>Sampled:</b> 11/11/21 14:02		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/22/21 15:29
<b>1322002-14</b>	<b>Sample Name:</b> Boys RR M N.B. <b>Sampled:</b> 11/11/21 14:01		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/22/21 15:29
<b>1322002-15</b>	<b>Sample Name:</b> Boys RR R N.B. <b>Sampled:</b> 11/11/21 14:01		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/22/21 15:29
<b>1322002-16</b>	<b>Sample Name:</b> STAFF RR L N.B. <b>Sampled:</b> 11/11/21 14:09		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/22/21 15:29
<b>1322002-17</b>	<b>Sample Name:</b> STAFF RR R N.B. <b>Sampled:</b> 11/11/21 14:09		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	3	ppb	2	15 ppb	11/22/21 15:29
<b>1322002-18</b>	<b>Sample Name:</b> Grils RR L N B <b>Sampled:</b> 11/11/21 14:05		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	6	ppb	2	15 ppb	11/23/21 14:07
<b>1322002-19</b>	<b>Sample Name:</b> Grils RR M N B <b>Sampled:</b> 11/11/21 14:05		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	<b>25</b>	ppb	2	15 ppb	11/23/21 14:07 <b>MCLE</b>
<b>1322002-20</b>	<b>Sample Name:</b> Grils RR R N B <b>Sampled:</b> 11/11/21 14:06		<b>Matrix:</b> Drinking Water				
+Lead	1030	EPA 200.9	7	ppb	2	15 ppb	11/23/21 14:07



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 11/29/2021  
Received: 11/16/2021  
Sampled By:  
Work Order: 1322002

**C** **Molalla River School District**  
**L** Attn: Tony Tiano  
**I** 412 S Sweigle Ave  
**E** Molalla OR, 97038  
**N** Phone: (503) 915-5248  
**T**

**Project:** Mulino Elementary School  
Project # : -  
Sample Type :

Sampling Location:

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
<b>1322002-21</b>	<b>Sample Name:</b> STAFF RM. FA N.BLDL. <b>Sampled:</b> 11/11/21 14:06							<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	11	ppb	2	15 ppb	11/23/21 14:07	
<b>1322002-22</b>	<b>Sample Name:</b> Room 2 FA <b>Sampled:</b> 11/11/21 14:20							<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/23/21 14:07	
<b>1322002-23</b>	<b>Sample Name:</b> Room 3 FA <b>Sampled:</b> 11/11/21 14:26							<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/23/21 14:07	
<b>1322002-24</b>	<b>Sample Name:</b> Room 4 FA <b>Sampled:</b> 11/11/21 14:27							<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/23/21 14:07	
<b>1322002-25</b>	<b>Sample Name:</b> Room 5 FA <b>Sampled:</b> 11/11/21 14:27							<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/23/21 14:07	
<b>1322002-26</b>	<b>Sample Name:</b> Room 6 FA <b>Sampled:</b> 11/11/21 14:25							<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/23/21 14:07	
<b>1322002-27</b>	<b>Sample Name:</b> Room 8 FA <b>Sampled:</b> 11/11/21 14:22							<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	2	ppb	2	15 ppb	11/23/21 14:07	
<b>1322002-28</b>	<b>Sample Name:</b> STAFF South BLDG. <b>Sampled:</b> 11/11/21 14:21							<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/23/21 14:07	
<b>1322002-29</b>	<b>Sample Name:</b> Boys RR L S. BLDG <b>Sampled:</b> 11/11/21 14:24							<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/23/21 14:07	
<b>1322002-30</b>	<b>Sample Name:</b> Boys RR R S. BLDG <b>Sampled:</b> 11/11/21 14:24							<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/23/21 14:07	



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 11/29/2021  
Received: 11/16/2021  
Sampled By:  
Work Order: 1322002

C  
L  
I  
E  
N  
T

**Molalla River School District**  
Attn: Tony Tiano  
412 S Sweigle Ave  
Molalla OR, 97038  
Phone: (503) 915-5248

**Project:** Mulino Elementary School  
Project # : -  
Sample Type :

Sampling Location:

---

**Lab Number**

**MCLE** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

**Note:** Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: \_\_\_\_\_

Adriana Gonzalez-Gray  
Laboratory Director