



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/25/2020
Received: 03/17/2020
Sampled By: Tony Tiano & Ric Dettwyler
Work Order: 0078007

C **Molalla River School District**
L Attn: Tony Tiano
I 412 S Sweigle Ave
E Molalla OR, 97038
N
T Phone: (503) 915-5248

Project:
Project # : -
Sample Type :

Sampling Location: Molalla Elementary School

Lab Number

| | Code | Method | Result | Units | MRL | EPA MCL* | Analysis Date/ Time |
|-------------------|---|-----------|-----------|-------|-----|----------|----------------------------|
| 0078007-01 | Sample Name: Entry Way Drinking Fountain Sampled: 3/12/20 8:30 | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/20/20 15:44 |
| 0078007-02 | Sample Name: Gym Boys RR Sink Sampled: 3/12/20 8:30 | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | 2 | ppb | 2 | 20 ppb | 03/20/20 15:44 |
| 0078007-03 | Sample Name: Staff RR Sink 1 Sampled: 3/12/20 8:30 | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/20/20 15:44 |
| 0078007-04 | Sample Name: Conf. Rm Office Sampled: 3/12/20 8:30 | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | 16 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-05 | Sample Name: Sick Rm Office RR Sink Sampled: 3/12/20 8:30 | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | 34 | ppb | 2 | 20 ppb | 03/23/20 15:39 MCLE |
| 0078007-06 | Sample Name: Staff Rm Sink Sampled: 3/12/20 8:30 | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-07 | Sample Name: Staff RR 2 Sink Sampled: 3/12/20 8:30 | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-08 | Sample Name: Girls Water Pod Rest Rm 1 Sampled: 3/12/20 8:30 | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | 2 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-09 | Sample Name: Girls Water Pod Rest Rm 2 Sampled: 3/12/20 8:30 | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-10 | Sample Name: Girls Water Pod Rest Rm 3 Sampled: 3/12/20 8:30 | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | 2 | ppb | 2 | 20 ppb | 03/23/20 15:39 |



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/25/2020
Received: 03/17/2020
Sampled By: Tony Tiano & Ric Dettwyler
Work Order: 0078007

C **Molalla River School District**
L Attn: Tony Tiano
I 412 S Sweigle Ave
E Molalla OR, 97038
N
T Phone: (503) 915-5248

Project:
Project # : -
Sample Type :

Sampling Location: Molalla Elementary School

Lab Number

| | Code | Method | Result | Units | MRL | EPA MCL* | Analysis Date/ Time |
|-------------------|---|-----------|----------------------|-------|-----|----------|----------------------------|
| 0078007-11 | Sample Name: Sky Pod Sink 1 Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 26 | ppb | 2 | 20 ppb | 03/23/20 15:39 MCLE |
| 0078007-12 | Sample Name: Sky Pod Sink 2 Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 4 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-13 | Sample Name: Earth Pod BR 1 Boys Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 3 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-14 | Sample Name: Earth Pod BR 2 Boys Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 2 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-15 | Sample Name: Earth Pod BR 3 Boys Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-16 | Sample Name: Annex BR Sink Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 4 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-17 | Sample Name: Annex Sink Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 5 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-18 | Sample Name: Library Sink Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 24 | ppb | 2 | 20 ppb | 03/23/20 15:39 MCLE |
| 0078007-19 | Sample Name: Flex Room Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 6 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-20 | Sample Name: Gym DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/25/2020
Received: 03/17/2020
Sampled By: Tony Tiano & Ric Dettwyler
Work Order: 0078007

C **Molalla River School District**
L Attn: Tony Tiano
I 412 S Sweigle Ave
E Molalla OR, 97038
N
T Phone: (503) 915-5248

Project:
Project # : -
Sample Type :

Sampling Location: Molalla Elementary School

Lab Number

| Lab Number | Code | Method | Result | Units | MRL | EPA MCL* | Analysis Date/ Time |
|-------------------|--|-----------|----------------------|-------|-----|----------|----------------------------|
| 0078007-21 | Sample Name: Water Pod Sink 1 Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 22 | ppb | 2 | 20 ppb | 03/23/20 15:39 MCLE |
| 0078007-22 | Sample Name: Water Pod Sink 2 Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 22 | ppb | 2 | 20 ppb | 03/23/20 15:39 MCLE |
| 0078007-23 | Sample Name: Gym G RR Sink Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 5 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-24 | Sample Name: Sky Pod Boys BR Sink 1 Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-25 | Sample Name: Sky Pod Boys BR Sink 2 Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-26 | Sample Name: Sky Pod Boys BR Sink 3 Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-27 | Sample Name: Water Pod RR Boys 1 Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-28 | Sample Name: Water Pod RR Boy 3 Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-29 | Sample Name: Girls Sky Pod BR 1 Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-30 | Sample Name: Girls Sky Pod BR 2 Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/25/2020
Received: 03/17/2020
Sampled By: Tony Tiano & Ric Dettwyler
Work Order: 0078007

C **Molalla River School District**
L Attn: Tony Tiano
I 412 S Sweigle Ave
E Molalla OR, 97038
N
T Phone: (503) 915-5248

Project:
Project # : -
Sample Type :

Sampling Location: Molalla Elementary School

Lab Number

| | Code | Method | Result | Units | MRL | EPA MCL* | Analysis Date/ Time |
|-------------------|---|-----------|----------------------|-------|-----|----------|----------------------------|
| 0078007-31 | Sample Name: Room 1 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 10 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-32 | Sample Name: Room 1 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 11 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-33 | Sample Name: Room 2 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 8 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-34 | Sample Name: Room 2 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 2 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-35 | Sample Name: Room 3 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 4 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-36 | Sample Name: Room 3 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 4 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-37 | Sample Name: Rm 4 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 8 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-38 | Sample Name: Rm 4 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-39 | Sample Name: Rm 5 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 51 | ppb | 4 | 20 ppb | 03/23/20 15:39 MCLE |
| 0078007-40 | Sample Name: Rm 5 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 11 | ppb | 2 | 20 ppb | 03/23/20 15:39 |



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/25/2020
Received: 03/17/2020
Sampled By: Tony Tiano & Ric Dettwyler
Work Order: 0078007

C **Molalla River School District**
L Attn: Tony Tiano
I 412 S Sweigle Ave
E Molalla OR, 97038
N
T Phone: (503) 915-5248

Project:
Project # : -
Sample Type :

Sampling Location: Molalla Elementary School

Lab Number

| | Code | Method | Result | Units | MRL | EPA MCL* | Analysis Date/ Time |
|-------------------|--|-----------|----------------------|-------|-----|----------|----------------------------|
| 0078007-41 | Sample Name: Rm 6 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 2 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-42 | Sample Name: Rm 6 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 3 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-44 | Sample Name: Rm 8 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 13 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-45 | Sample Name: Rm 9 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 21 | ppb | 2 | 20 ppb | 03/23/20 15:39 MCLE |
| 0078007-46 | Sample Name: Rm 9 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 5 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-47 | Sample Name: Rm 10 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 4 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-48 | Sample Name: Rm 10 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 2 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-49 | Sample Name: Rm 11 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 4 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-50 | Sample Name: Rm 11 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-51 | Sample Name: Rm 12 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 4 | ppb | 2 | 20 ppb | 03/23/20 15:39 |



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/25/2020
Received: 03/17/2020
Sampled By: Tony Tiano & Ric Dettwyler
Work Order: 0078007

C **Molalla River School District**
L Attn: Tony Tiano
I 412 S Sweigle Ave
E Molalla OR, 97038
N
T Phone: (503) 915-5248

Project:
Project # : -
Sample Type :

Sampling Location: Molalla Elementary School

Lab Number

| Lab Number | Code | Method | Result | Units | MRL | EPA MCL* | Analysis Date/ Time |
|-------------------|--|-----------|----------------------|-------|-----|----------|---------------------|
| 0078007-52 | Sample Name: Rm 12 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 3 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-53 | Sample Name: Rm 13 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-54 | Sample Name: Rm 13 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 2 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-55 | Sample Name: Rm 14 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 7 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-56 | Sample Name: Rm 14 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 3 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-57 | Sample Name: Rm 15 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 6 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-58 | Sample Name: Rm 15 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 4 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-59 | Sample Name: Rm 16 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 7 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-60 | Sample Name: Rm 16 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 4 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-61 | Sample Name: Rm 17 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 4 | ppb | 2 | 20 ppb | 03/23/20 15:39 |



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/25/2020
Received: 03/17/2020
Sampled By: Tony Tiano & Ric Dettwyler
Work Order: 0078007

C **Molalla River School District**
L Attn: Tony Tiano
I 412 S Sweigle Ave
E Molalla OR, 97038
N
T Phone: (503) 915-5248

Project:
Project # : -
Sample Type :

Sampling Location: Molalla Elementary School

Lab Number

| | Code | Method | Result | Units | MRL | EPA MCL* | Analysis Date/ Time |
|-------------------|---|-----------|----------------------|-------|-----|----------|----------------------------|
| 0078007-62 | Sample Name: Rm 17 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 6 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-63 | Sample Name: Rm 18 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 6 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-64 | Sample Name: Rm 18 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 6 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-65 | Sample Name: Rm 19 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 3 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-66 | Sample Name: Rm 19 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 2 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-67 | Sample Name: Rm 20 FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 11 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-68 | Sample Name: Rm 20 DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 2 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-69 | Sample Name: Earth Pod Sink 1 Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 30 | ppb | 2 | 20 ppb | 03/23/20 15:39 MCLE |
| 0078007-70 | Sample Name: Earth Pod Sink 2 Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 8 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-71 | Sample Name: Kitchen Hand Sink Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 4 | ppb | 2 | 20 ppb | 03/23/20 15:39 |



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/25/2020
Received: 03/17/2020
Sampled By: Tony Tiano & Ric Dettwyler
Work Order: 0078007

C **Molalla River School District**
L Attn: Tony Tiano
I 412 S Sweigle Ave
E Molalla OR, 97038
N
T Phone: (503) 915-5248

Project:
Project # : -
Sample Type :

Sampling Location: Molalla Elementary School

Lab Number

| | Code | Method | Result | Units | MRL | EPA MCL* | Analysis Date/ Time |
|-------------------|--|-----------|----------------------|-------|-----|----------|---------------------|
| 0078007-72 | Sample Name: Kitchen K 1 Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 2 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-73 | Sample Name: Kitchen K 2 Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 6 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-74 | Sample Name: Girls RR 1 Earth Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-75 | Sample Name: Girls RR 2 Earth Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-76 | Sample Name: Girls RR 3 Earth Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 2 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-77 | Sample Name: Title 1 Rm DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-78 | Sample Name: Title 1 Rm FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 10 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-79 | Sample Name: Cafe Drinking Fountain Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 15 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-80 | Sample Name: Rm 33 Spec. Ed DF Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 5 | ppb | 2 | 20 ppb | 03/23/20 15:39 |
| 0078007-81 | Sample Name: Rm 33 Spec. Ed FA Sampled: 3/12/20 8:30 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 7 | ppb | 2 | 20 ppb | 03/23/20 15:39 |



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/25/2020
Received: 03/17/2020
Sampled By: Tony Tiano & Ric Dettwyler
Work Order: 0078007

C **Molalla River School District**
L Attn: Tony Tiano
I 412 S Sweigle Ave
E Molalla OR, 97038
N Phone: (503) 915-5248
T

Project:
Project # : -
Sample Type :

Sampling Location: Molalla Elementary School

Lab Number

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director