



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/06/2019
Received: 02/20/2019
Sampled By: Tony Tiano
Work Order: 9051011

C **Molalla River School District**
L Attn: Frederic Dettwyler
I PO Box 188
E Molalla OR, 97037
N Phone: (503) 829-2359
T

Project:
Project # : N/A
PWSID # : 4190529

Sampling Location: Rural Dell Elem.
Sample Matrix: Drinking Water

Lab Number

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
9051011-01 Sample Name: Rm 1 Sampled: 2/20/19 7:45							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00
9051011-02 Sample Name: Rm 2 Sampled: 2/20/19 7:47							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00
9051011-03 Sample Name: Rm 3 Sampled: 2/20/19 7:50							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00
9051011-04 Sample Name: Rm 4 Sampled: 2/20/19 7:51							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00
9051011-05 Sample Name: Rm 5 Sampled: 2/20/19 7:52							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00
9051011-06 Sample Name: Rm 6 Sampled: 2/20/19 7:55							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/06/2019
Received: 02/20/2019
Sampled By: Tony Tiano
Work Order: 9051011

C Molalla River School District
L Attn: Frederic Dettwyler
I PO Box 188
E Molalla OR, 97037
N Phone: (503) 829-2359
T

Project:
Project # : N/A
PWSID # : 4190529

Sampling Location: Rural Dell Elem.
Sample Matrix: Drinking Water

Lab Number

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
9051011-07 Sample Name: Rm 7 Sampled: 2/20/19 7:55							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00
9051011-08 Sample Name: Rm 8 Sampled: 2/20/19 7:57							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00
9051011-09 Sample Name: Rm 9 Sampled: 2/20/19 7:58							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00
9051011-10 Sample Name: Rm 10 Sampled: 2/20/19 8:01							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
A = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.